



(ISO 9001 : 2015 Certified Testing Firm)

## CERTIFICATE OF COMPLIANCE

for

**PT. CICOR PANATEC**

*Jalan Beringin Lot 323 & 324  
Batamindo Industrial Park Muka Kuning Batam Kepri  
Indonesia*

### CLEANROOM, LEVEL 1

- CRA 1 (ISO CLASS 7)
- CRA 2 (ISO CLASS 7)
- CRA 3 (ISO CLASS 7)
- CHANGE ROOM (ISO CLASS 7)

As per requirements of ISO 14644-1:2015(E), the designated area(s) listed above has met the acceptance criteria for Air Cleanliness ISO Class 7 under **OPERATIONAL Condition**. Testing results and details are attested to in the report no: **AXM-R3266**.



**Luo ZhiBang**  
NEBB CPT Professional

Certification Date : 08 February 19

Certification Expiry Date : 08 February 20