



(ISO 9001: 2015 Certified Testing Firm)

CERTIFICATE OF COMPLIANCE

for

PT. CICOR PANATEC

Jalan Beringin Lot 323 & 324 Batamindo Industrial Park Muka Kuning Batam Kepri Indonesia

INJECTION MOULDING - ISO CLASS 7 -

As per requirements of ISO 14644-1:2015(E), the designated area(s) listed above has met the acceptance criteria for Air Cleanliness ISO Class 7 under OPERATIONAL Condition. Testing results and details are attested to in the report no: AXM-R3305.

yom TAB Pte Lio Exp. 31/03/20 Performance

Luo ZhiBang

NEBB CPT Professional

Certification Date

: 27 February 19

Certification Expiry Date: 27 February 20